

DUCT SEALER VOC CONTENT

VALIANT ENVIRONMENTAL COMPOUNDS PTY. LTD.

ABN 87 105 878 555

PO Box 648. Padstow N.S.W. 2211

PHONE (02) 9792 5799

EMAIL: valiant@environments.com.au



1. PRODUCT – Fire Rated Duct Sealant

For the purposes of this certification this product is considered to be Architectural Sealant.

2. VOC INFORMATION

For the purposes of this certification VOC's are defined as:

Any volatile compound of carbon having an initial boiling point less than or equal to 250°C measured at a standard atmospheric pressure of 101.3 kPa excluding methane, carbon monoxide, carbon dioxide, carbonic acid, metallic carbides or carbides, ammonium carbonate, and exempt compounds.

3. CERTIFICATION

On the basis of the above information we are able to certify that our Fire Rated duct sealant has VOC levels (without water and without exempt compounds) of 115.9g/litre and an overall level of 4.5% by weight

The TVOC of this product has been calculated theoretically, based on the known VOC values of the individual raw material components using calculations carried out in accordance with the South Coast Air Quality Management District Rule 1168 for testing methods and exempt compounds and the British Coatings Industry VOC Labelling Scheme.

This product fits into the Low VOC content band of 0.3% to 7.99%.

Signed,

Ross Warner
Technical Director
Valiant Environmental Compounds Pty. Ltd.
26th August 2025